







# CONSTRUCTION MATERIALS

## TECHNOLOGIES INITIAL Test Results Report

Company Name:  Volatile Free

Product Brand Name & Model:  VFI-610

Panel ID <u> 7 </u>	Coating Thickness	Panel ID <u> 8 </u>	Coating Thickness	Panel ID <u> 9 </u>	Coating Thickness
	1. 26		1. 27		1. 34
	2. 25		2. 26		2. 32
	3. 31		3. 30		3. 36
	4. 24		4. 24		4. 39
	5. 28		5. 27		5. 36
	Batch Ave. 27		Batch Ave. 27		Batch Ave. 35


18e. Average for all initial thickness tests (2 decimal places): Coating Thickness  31  mils

18f. Within 10% tolerance of manufacturer recommendation (see box 11a)  (check box to confirm)

**19. Tests conducted:**

Type	Initial Test Date
<input type="checkbox"/> E903 Test	Date _____
<input type="checkbox"/> E1918 Test	Date _____
<input checked="" type="checkbox"/> C1549 Test	Date <u> 12/20/07 </u>
<input checked="" type="checkbox"/> C1371 Test	Date <u> 12/20/07 </u>
<input type="checkbox"/> CRRC-1 Method #1	Date _____
<input type="checkbox"/> D1669 Test	Date _____

20. The undersigned certifies that, to the best of his/her knowledge, the measurements contained herein are true and accurate:

Donald C. Portfolio  
 Responsible Person's Printed Name  
  
 Responsible Person's Signature (Initial Tests)      December 27, 2007  
 Date

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.